



Del Frate
RECEIVED
SACRAMENTO
CYRWQCB
13 OCT 31 PM 2:21

October 31, 2013

Mr. Todd Del Frate
California Regional Water Quality Control Board
Central Valley Region
11020 Sun Center Drive, #200
Rancho Cordova, CA 95670-6114

Re: Update Report for Repair of Subsurface Pipelines and Paved Surfaces at LF-1 and Feather River Organics Temporary Storm Water Collection System, Recology Yuba Sutter, Yuba County, California

Dear Mr. Del Frate:

In response to your letter dated December 03, 2012, Recology Yuba Sutter is transmitting the following update report on the repairs to the subsurface pipelines and paving identified in the November 15, 2012 and March 14, 2013 Golder Associates' reports.

The pipelines and paving project is complete. A Construction Quality Assurance report will be submitted in accordance with Cleanup and Abatement Order R5-2013-0704, Order #3. This letter will serve as the final monthly update for this project.

Recology Yuba-Sutter is currently in the process of improving the storm water collection and management system at Feather River Organics. The system improvements are designed to collect run-off from the pad for eventual collection in above ground storage tanks. Collected and stored run-off will either be reused in the composting process or discharged to sanitary sewer on site.

The following items have been completed:

- A series of 6-inch PVC drainage pipes have been installed at 100 foot intervals within the screening berm.
- Two, 21,000 gallon storage tanks have been installed on the compost pad near the flare compound.
- A diversion berm has been constructed to direct pad run-off to the culvert pipes.
- Two shallow sumps have been installed near the facility entrance to collect run-off from the southern portion of the pad.
- A single, 21,000 gallon storage tank has been installed between the shallow sumps for collection and temporary storage of runoff from the southern portion of the pad.

The site is in the process of making the following improvements to the system:

- Installation of a 4,000 gallon collection tank/vault at the termination of the drainage culvert to the Hog Farm.
- Construction of a shallow drainage ditch along the western edge of the southern portion of the pad to help convey water to a shallow collection sump.
- A small berm adjacent to the grass-lined swale will be built to help direct run-off to the sumps at the southern portion of the swale
- Completion of electrical connections to power the pump systems

If you have any questions or require additional information, please contact me at (707) 693-2107.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Jordan Norris', with a stylized, flowing script.

Jordan Norris
Environmental Specialist

cc: Paul Donoho, Yuba County Environmental Health
Terry Bentley, Recology Yuba Sutter
Phil Graham, Feather River Organics